

STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

PERMIT

TO APPROPRIATE PUBLIC WATERS OF THE STATE OF WASHINGTON

☐ Surface Water (Issued in accordance with the provisions of Chapter 117, Laws of Washington for 1917, and amendments thereto, and the rules and regulations of the Department of Ecology.)

☒ Ground Water (Issued in accordance with the provisions of Chapter 263, Laws of Washington for 1945, and amendments thereto, and the rules and regulations of the Department of Ecology.)

PRIORITY DATE August 13, 1991	APPLICATION NUMBER G2-28244	PERMIT NUMBER G2-28244	CERTIFICATE NUMBER
----------------------------------	--------------------------------	---------------------------	--------------------

NAME
Sara Lee O'Connor c/o Bell Hill Realty

ADDRESS (STREET) Post Office Box 507	(CITY) Sequim	(STATE) Washington	(ZIP CODE) 98382-0507
---	------------------	-----------------------	--------------------------

The applicant is, pursuant to the Report of Examination which has been accepted by the applicant, hereby granted a permit to appropriate the following described public waters of the State of Washington, subject to existing rights and to the limitations and provisions set out herein.

PUBLIC WATERS TO BE APPROPRIATED

SOURCE
A well

TRIBUTARY OF (IF SURFACE WATERS)

MAXIMUM CUBIC FEET PER SECOND	MAXIMUM GALLONS PER MINUTE 70	MAXIMUM ACRE-FEET PER YEAR 27.5
-------------------------------	----------------------------------	------------------------------------

QUANTITY, TYPE OF USE, PERIOD OF USE 27.5 acre-feet per year	Multiple domestic supply	Year-round, as needed
---	--------------------------	-----------------------

LOCATION OF DIVERSION/WITHDRAWAL

APPROXIMATE LOCATION OF DIVERSION-WITHDRAWAL
300 feet south and 1,200 feet east of the northwest corner of Section 34.

LOCATED WITHIN (SMALLEST LEGAL SUBDIVISION) N $\frac{1}{2}$ NW $\frac{1}{4}$	SECTION 34	TOWNSHIP N. 30	RANGE, (E. OR W.) W.M. 3W	W.R.I.A. 17	COUNTY Clallam
---	---------------	-------------------	------------------------------	----------------	-------------------

RECORDED PLATTED PROPERTY

LOT	BLOCK	OF (GIVE NAME OF PLAT OR ADDITION)
-----	-------	------------------------------------

LEGAL DESCRIPTION OF PROPERTY ON WHICH WATER IS TO BE USED

Area served by Bayview Acres within Section 27, 28, 33, 34, T. 30 N., R. 3 W.W.M., Clallam County, State of Washington.

DESCRIPTION OF PROPOSED WORKS

A 8" x 499' well to discharge 70 gpm to a 50,000 gallon storage reservoir, associated mainline, and system design for distribution to 55 connections.

DEVELOPMENT SCHEDULE

BEGIN PROJECT BY THIS DATE:

Started

COMPLETE PROJECT BY THIS DATE:

July 1, 1995, 1996

WATER PUT TO FULL USE BY THIS DATE:

July 1, 1996

2003 1998

7/1/2002 2003

2003 2004

2008

2005

PROVISIONS

Installation and maintenance of an access port as described in WAC 173-160-355 is required. An air line and gauge may be installed in addition to the access port.

An approved metering device shall be installed and maintained in accordance with RCW 90.03.360, WAC 508-64-020 through -040 (installation, operation, and maintenance requirements are attached). Meter readings shall be recorded at least monthly.

In order to maintain a sustainable supply of water, pumping must be managed so that static water levels do not progressively decline from year to year. Water levels shall be measured and recorded monthly, using a consistent methodology. The length of the pumping period or recovery period prior to each measurement shall be constant, and shall be included in the record. Data shall be submitted annually, in the month of February, to the Department of Ecology.

In conjunction with the State Department of Health bacteriological sampling the applicant shall test water quality for chloride concentration once every three months. Water samples shall be gathered and analyzed in accordance with Standard Methods for the Examination of Water and Wastewater, 16th Edition, 1985, or equivalent methods. Chloride concentration analysis shall be performed by a laboratory accredited by the Department of Ecology for the tests to be conducted. Accreditation information may be obtained for Ecology's quality Assurance Program at (206) 895-4649.

When the chloride concentration exceeds 100 mg/L, the withdrawal rate shall be reduced or the pump setting raised to reduce the chloride level to below 100 mg/L.

Under RCW 90.44.250 and 90.54.030, the Department of Ecology is directed to become informed about all aspects of the water resources of the State. The Department is authorized to make such investigations as may be necessary to determine the location, extent, depth, volume, and flow of all ground waters within the State. Accordingly, the applicant shall monitor and provide an annual summary of the previous year's monthly water level data and monthly totals of water pumped for this well. The summary shall be submitted in tabular format to Ecology's Southwest Regional Office annually, during the month of February, or more frequently if requested by the Department.

This permit shall be subject to cancellation should the permittee fail to comply with the above development schedule and/or fail to give notice to the Department of Ecology on forms provided by that Department documenting such compliance.

Given under my hand and the seal of this office at Olympia, Washington,

this 19th day of August, 19 94.

Mary Riveland, Director

Department of Ecology

ENGINEERING DATA

OK gb

by Gale Blomstrom

The Permittee is advised that notice of proof of appropriation of water (under which the final certificate of water right is issued) should not be filed until the permanent diversion facilities have been installed, and the system is currently in use. This includes installation of a mainline system capable of delivering the recommended quantity of water to an existing or proposed distribution system within the area to be served, and fulfillment of all other terms of this permit.

This permit may be subject to implementation of the minimum requirements established in the Conservation Planning Requirements, Guidelines and Requirements for Public Water Systems Regarding Water Use Reporting, Demand Forecasting Methodology, and Conservation Programs, July 1994, and as revised.

Under RCW 90.03.005 and 90.54.020(6), conservation and improved water use efficiency must be emphasized in the management of the State's water resources, and must be considered as a potential new source of water. Accordingly, as part of the terms of this permit, the applicant may be required to prepare and implement a water conservation plan approved by Department of Health. The standards for such a plan may be obtained from either the Department of Health or the Department of Ecology.



Supporting Docs for Permit Issuance

Document Type Code - 5
(Bar-code C39HrP36DITt, Font 48)

S



pd 20 ✓ 31669

RECEIVED

'94 JUL 14 A9:35

DEPARTMENT OF ECOLOGY
SW REGIONAL OFFICE

62-28247

July 11, 1994

Gale Blomstrom
Water Resources Supervisor
Department of Ecology
PO Box 47775
Olympia, WA
98504-7775

Dear Gale:

Thank you for your letter of July 7 informing me that my application for a ground water permit for Bell Woods has been approved.

I am enclosing a check for \$20.

We intend to submit a water conservation plan, as soon as we receive proper instructions on how to go about this. I have put in a phone call to Vicki Windust to facilitate our response.

Once more, thank you for your help--and the good news.

Sincerely,

Sara Lee O'Connor

Sara Lee O'Connor



STATE OF WASHINGTON
DEPARTMENT OF ECOLOGY

PO Box 47775 • Olympia, Washington 98504-7775 • (206) 407-6300

July 7, 1994

Sara Lee O'Connor
c/o Bell Hill Realty
Post Office Box 507
Sequim, WA 98382-0507

Dear Ms. O'Connor

Re: Ground Water Permit No. G 2-28244

Your application has been approved. A permit will be issued after the required 30 day appeal period and upon payment of the statutory fee. Enclosed is the Report of Examination summarizing our findings and recommendations.

Issuance of this permit is an appealable decision under Chapter 43.21B Revised Code of Washington. To submit an appeal, contact the Pollution Control Hearings Board of Washington, within 30 days of receiving this letter. A copy of the appeal should also be sent to the Director of the Department of Ecology. Procedures for requesting a hearing may be obtained from this department.

Please send your permit fee of \$20.00 within 30 days. Make your check payable to Department of Ecology.

Sincerely,

Gale Blomstrom
Water Resources Supervisor

GB:ds
Enclosure

